



Number	19GR0292/00	Replaces	--
Issue date	06-06-2019	Contract number	E8090
Due date	06-06-2029	Module	B (Type testing)
Report number	180800005	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063CU3005		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the condensing central heating boilers, type(s):

Puma Condens 18/24 MKV-AS/1 (H-TR)

Manufacturer **Protherm Production s.r.o.
Skalica, Slovakia**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Ronald Karel, Kiwa



Number 19GR0292/00 Replaces --

Issue date 06-06-2019 Contract number E8090

Due date 06-06-2029 Module B (Type testing)

Report number 180800005 Scope (EU) 2016/426 (9 March 2016)

PIN 0063CU3005 Page 1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
Protherm Production s.r.o.

Types:

Model name	Heat input (G20)		Heat input (G31)	
	CH (kW - Hi)	DHW (kW - Hi)	CH (kW - Hi)	DHW (kW - Hi)
Puma Condens 18/24 MKV-AS/1 (H-TR)	6.2 – 18.8	6.2 - 24	8.4 – 18.8	8.4 - 24

Model name	Appliance categories		Countries
Puma Condens 18/24 MKV-AS/1 (H-TR)	II _{2H3P}	G20-20mbar G31-37mbar	Turkey

Model name	Appliance types	Flue installation manuals (use latest version)	Article number
Puma Condens 18/24 MKV-AS/1 (H-TR)	B _{53P} , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₈₃ , C ₉₃	0020289283	0010026101