



Number	25GR0241/00	Replaces	--
Issue date	15-07-2025	Contract number	E 8090
Due date	15-07-2035	Module	B (Type testing)
Report number	P000489807	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DQ3807		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the **condensing boilers**, model(s):

**Puma Condens 24/24 MKV-AS/2 (H-TR),
Puma Condens 28/28 MKV-AS/2 (H-TR)**

Manufacturer

**Protherm Production s.r.o.
Jurkovičova 45
909 01 Skalica
Slovakia**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-2-1:2022+A1:2023 and EN 15502-1:2021+A1:2023

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Wilmersdorf 50
P.O. Box 137
7300 AC APELDOORN
The Netherlands

<https://www.kiwaenergy.com>





Number	25GR0241/00	Replaces	-
Issue date	15-07-2025	Contract number	E 8090
Due date	15-07-2035	Module	B (Type testing)
Report number	P000489807	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DQ3807	Page	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
Protherm Production s.r.o.

Model(s):

Model name	Heat input	
	CH (kW – Hi)	DHW (kW – Hi)
Puma Condens 24/24 MKV-AS/2 (H-TR)	3.6 – 24	3.6 - 24
Puma Condens 28/28 MKV-AS/2 (H-TR)	4.2 – 28	4.2 – 28

Model name	Appliance categories		Countries
Puma Condens 24/24 MKV-AS/2 (H-TR)	I _{2H}	G20 – 20 mbar	Turkey
Puma Condens 28/28 MKV-AS/2 (H-TR)			

Model name	Appliance types	Flue installation manuals (use latest version)
Puma Condens 24/24 MKV-AS/2 (H-TR)	C ₁₃ ., C ₃₃ , C ₉₃ , B _{53P}	8000037582
Puma Condens 28/28 MKV-AS/2 (H-TR)		

Remarks:

--